

# Hurricane Douglas Adv. 17


For Planning Purposes Only!

WASHINGTON, DC 15:45:45 24 Jul 2020

CHICAGO 14:45:45 24 Jul 2020 LOS ANGELES 12:45:45 24 Jul 2020

https://simsuite.usace.army.mil/wab/v2.14/index.html?config=config-2.json& 65=101

Updated as of 24 Jul 2020 (2:45 PM Central Daylight Time)



#### **Critical Infrastructure Summary**

**Total** 


396 structures

Power Requirements



#### Generators

By Generator Count



#### **Tropical Cyclone Track and Forecasts (for mission models)**



This web map references the live tiled map service from the OpenStreetMap (OSM) project. OpenStreetMap (OSM) is an open collaborative project to create a free editable map of the ...

NOAA/NOS/OCS nowCOAST, NOAA/NWS/NHC, NOAA/NWS/CPHC | @ 2020 Microsoft Corporation, @ 2020 HERE

## **Mission Summary**



The mission models account for storm surge and wind damage only, but do not account for other related storm hazards that may affect the mission estimates.

Mission Summary	
Total Counties	3
Debris (cu. yd.)	587,677
Temporary Roofing (units)	1,083
Population	1,175,299
Households	391,684

Population Distribution	
Category 1	1,018,535

### **Debris**



### Temporary Roofing



# **Population**



## Households



HAWAII	Yards of Debris (587,677)	Roof Units (1,083)	Population (1,175,299)	Households (391,684)
KAUAI	40,584	75	54,926	23,369
MAUI	0	0	156,764	53,291
OAHU	547,093	1,008	963,609	315,024

### **Critical Infrastructure**

Summary	
Total Structures	396
Power Requirements	15,282.1

### Range (kW)

Communications	# FED Gen Req	Range (kW)	Req kW
AM Antennas (7)	0.4	35 - 75	19.3
Cellular Towers (25)	15.0	35 - 75	825.0
FM Antennas (27)	1.4	35 - 75	74.3

Education	# FED Gen Req	Range (kW)	Req kW
Private Schools (26)	0.0	200 - 300	0.0
Public Schools (88)	26.4	200 - 300	6,600.0
Colleges and Universities (4)	0.1	200 - 300	20.0

Emergency Services	# FED Gen Req	Range (kW)	Req kW
911 Call Centers (0)	0.0	15 - 35	0.0
Emergency Medical Service (16)	1.6	15 - 35	40.0
Fire Stations (23)	2.3	15 - 35	57.5
Service Providers (0)	0.0	0 - 0	0.0

Healthcare	# FED Gen Req	Range (kW)	Req kW
Nursing Homes (11)	1.6	35 - 100	111.4
Hospitals (7)	2.1	800 - 2000	2,940.0
Urgent Care Facilities (2)	0.4	200 - 300	100.0

Military	# FED Gen Req	Range (kW)	Req kW
Air National Guard (ANG) Sites (2)	0.0	15 - 35	0.0
Army National Guard (ARNG) Sites (4)	0.0	15 - 35	0.0
National Security Government Military Facilities (110)	0.0	15 - 35	0.0

Law Enforcement	# FED Gen Req	Range (kW)	Req kW
Prison Points (4)	0.8	400 - 600	400.0
Local Police (4)	0.4	15 - 35	10.0
State Police (1)	0.1	15 - 35	1.3
Correctional Facilities (0)	0.0	400 - 600	0.0

State and Local EOC	# FED Gen Req	Range (kW)	Req kW
Local Emergency Operations Centers (1)	0.2	15 - 40	5.5
State Emergency Operation Centers (EOCs) (0)	0.0	15 - 35	0.0

State Facilities	# FED Gen Req	Range (kW)	Req kW
Governors Mansion (0)	0.0	100 - 200	0.0
Major State Government Building (1)	0.1	100 - 200	15.0

Transportation	# FED Gen Req	Range (kW)	Req kW
Ports (4)	0.0	600 - 1200	0.0
Amtrak Stations (0)	0.0	100 - 300	0.0
Bus Stations (5)	0.0	100 - 300	0.0
Intermodal Terminal Facilities (0)	0.0	100 - 300	0.0
Railroad Stations (0)	0.0	100 - 300	0.0
Public-Use Airports (17)	2.0	40 - 100	142.8

Water	# FED Gen Req	Range (kW)	Req kW
Water Treatment Facilities (0)	0.0	800 - 2000	0.0
Wastewater Treatment Plants (7)	2.8	800 - 2000	3,920.0

Report Generated by SimSuite https://simsuite.usace.army.mil/wab/v2.14/index.html?config=config-2.json& 65=101