

INDEX

- Absorption, subsurface-2
- Activated carbon, adsorption of: 3-6, 9-2, 15-6
- Activated sludge: 13-1-13-3
 - aeration systems: 13-3
 - diffused air: 13-3
 - mechanical: 13-3
 - aeration tanks: 13-
 - detention time: 13-3
 - aerators (*see Aerators*)
 - air
 - required capacity: 13-3
 - design considerations
 - oxygen requirements: 13-3
 - final tanks (*See sedimentation tanks*)
 - process modifications: 13-2
 - complex mix: 13-2
 - contact stabilization: 13-2
 - conventional: 13-2
 - extended aeration: 13-2
 - step aeration: 13-2
 - settling tanks: 13-2
- Advanced wastewater treatment: 3-5, 9-2, 15-1-15-10
 - biological unit processes
 - denitrification: 15-10
 - nitrification: 15-9
 - polishing ponds: 15-2
 - Post-aeration: 15-3
 - land application: 15-8
 - chemical unit processes
 - carbon adsorption: 9-2, 15-6
 - phosphorus removal: 15-7
 - physical unit operations
 - filtration: 3-5, 15-5
 - microstrainers: 3-5, 15-4
 - unit operations and processes: 15-1
 - application data: 15-1
 - selection: 5-1-5-3
- Aerated pit latrine: 6-3
 - Aerators
 - diffused air: 13-3
 - mechanical: 13-3
 - surface: 13-3
- Aerobic sludge digestion: 3-5, 16-6
 - advantages: 16-6
 - process description: 16-6
 - process design: 16-6
 - process operation: 16-6

TM 5-814-3/AFM 88-11, Volume III

Air blowers (*See Blowers*)

Alum

reactions involving: 15-7

Anaerobic sludge digestion: 3-5, 16-6

digester gas (*See Digester gas*)

digestion tanks

conventional: 16-6

high rate: 16-6

temperature: 16-6

two stage: 16-6

Bar racks: 10-2

head losses: 10-2

Biochemical oxygen demand (BOD)

typical values in wastewater: 4-7

Biofiltration (*See Trickling filters*)

Biological characteristics of wastewater (See Wastewater characteristics, biological)

Biological treatment (*See Biological unit processes*)

Biological unit processes

activated sludge: 13-1-13-6

anaerobic digestion: 3-5, 16-6

denitrification: 15-10

nitrification: 15-9

ponds: 14-1-14-4

stabilization ponds: 14-1-14-4

trickling filters: 12-1-12-5

upgrading activated sludge: 8-4

upgrading trickling filters: 8-3

upgrading ponds: 8-5

BOD (*See Biochemical oxygen demand*)

Calcium hydroxide: 15-7

characteristics: 15-7

reactions involving: 15-7

recalcining: 15-7

uses: 15-7

Carbon Adsorption: 3-5, 9-2, 15-6

Calcium hypochlorite: 17-2

Centrifugation: 16-5

Chemical characteristics of wastewater: 4-7

Chemical coagulation (*See Chemical precipitation*)

Chemical precipitation: 11-5

chemicals: 11-5

of phosphorus (*See phosphorus removal by precipitation*)

Chemical toilets: 6-3

Chlorination

application

disinfection: 17-1

dosages: 17-2

feeders: 17-3

Chlorination
 capacity required: 17-2
 for chlorine: 17-2
 for hypochlorite: 17-2
 chlorine contact chambers: 17-2
 design considerations: 17-2
 detention time: 17-2
 Clarification: 5, 11-2, 12-4
 flocculation: 10-6, 11-2
 COD (*See Chemical oxygen demand*)
 Column filters (*See filters, upflow*)
 Comminutors: 10-3
 design considerations: 10-3
 Complete-mix activated sludge: 13-2 (*See also Activated sludge*)
 Contact stabilization activated sludge (*See Activated sludge*)
 Denitrification: 15-10
 Design considerations: 1-4, 4-1-4-7
 future demand: 4-3
 population: 4-2
 wastewater volume: 4-4
 Dewatering of sludge (*See Sludge dewatering*)
 Digester: 16-6
 Disinfection: 17-1-17-5
 with chlorine: 17-2
 definition: 17-2
 Dissolved oxygen (DO)
 requirements in treatment: 13-4, 14-3
 solubility in water: C-1
 DO (*See Dissolved oxygen*)
 Efficiency
 of treatment processes: 3-5
 activated sludge: 3-5
 advanced: 3-5
 primary sedimentation: 3-5
 Effluent standards: 5-1
 Extended aeration, activated sludge (*See Activated sludge*)
 Ferric chloride: 15-7
 Ferric sulfate: 15-7
 Filters, trickling (*See Trickling filters*)
 Filtration: 3-5
 gravity: 3-5, 15-5
 pressure: 3-5, 15-5
 subsurface: 6-4
 Flotation: 10-5
 Flow measurement: 18-1-18-2
 methods: 18-2
 magnetic flow meters: 18-2
 Parshall flumes: 18-2
 Venturi meters: 18-2
 weirs: 18-2

TM 5-814-3/AFM 88-11, Volume III

Flume, Parshall (*See Parshall flume*)
Gas, digester (*See Digester*)
Grinders (*See Comminutors*)
Grit chambers: 10-4
 horizontal flow
 control section: 10-4
 design considerations: 10-4
Incineration: 3-6
 Imhoff tanks: 6-6
 incineration toilets: 6-3
 inhibitory compounds: 3-1
Irrigation: 15-8
Laboratory requirements: F-1
Lagoons (*See Ponds, stabilization*)
Land application systems: 15-8
 natural wetlands: 15-8
 overland flow: 15-8
 rapid infiltration: 15-8
Latrine (*See Aerated pit latrine*)
Leaching wells: 6-2
Lime (*See Calcium hydroxide*)
Loss of head (*See head loss*)
Magnetic flow meter: 18-2
Measurement of flowing water (*See Flow measurement*)
Mechanical aerators: 13-4
Metering: 18-3
Microstraining: 11-7, 15-4
Mixing
 application
 in aerated lagoons: 14-2
 in chlorination: 17-2
Mound systems: 6-5
National Research Council (NRC)
 trickling filter equations: 12-2
Nitrification
 in wastewater treatment: 15-9
Nitrogen removal
 by denitrification: 15-10
 from wastewater: 15-9
Oxidation
 with ozone (*See Activated sludge*)
Oxidation ponds (*See Ponds, stabilization*)
Oxygen (*See Dissolved oxygen*)
Ozone
 disinfection by: 17-5

- Package treatment plants: 6-7
- Parshall flume
 - for flow measurement: 18-2
- Percolation tests: 6-2
- Phosphorus removal: 15-7
 - with alum: 15-7
 - with calcium: 15-7
 - chemical dosages required: 15-7
 - with iron: 15-7
- Physical characteristics of wastewater (*See Wastewater characteristics, physical*)
- Pit latrine (*See Aerated pit latrine*)
- Plant layout: 9-4
- Polishing pond: 14-1-14-4
- Polyelectrolytes: 6-, 11-5
- Polymers (*See Polyelectrolytes*)
- Ponds, stabilization: 14-1-14-4
 - aerobic-anaerobic (facultative): 14-2
 - aerobic pond design: 14-2
 - anaerobic: 14-2
 - classification: 14-2
 - definition: 14-2
 - design parameters: 14-3
 - mixing: 14-3
- Population equivalent: 4-5
- Positive displacement pumps: 16-2
- Post-aeration: 15-3
- Precipitation
 - chemical (*See Chemical precipitation*)
 - of phosphorus (*See Phosphorus removal, by precipitation*)
 - sedimentation (*See Sedimentation tanks, Sedimentation theory*)
- Preliminary treatment: 3-2, 9-1, 10-1-10-6
- Pretreatment: 3-1
- Primary sedimentation tanks: 11-2
 - depths: 11-3
 - design criteria: 11-2
 - detention times: 11-2
 - inlets and outlets: 11-3
 - overflow rates: 11-2
 - purpose: 11-1
 - removal efficiencies: 11-2
 - scum removal: 11-3
 - surface loading rates: 11-2
 - types
 - circular: 11-3
 - rectangular: 11-3
 - weir loading: 11-2

TM 5-814-3/AFM 88-11, Volume III

Primary treatment: 3-3, 3-6, 9-1, 11-1-11-7

Pure oxygen activated sludge (*See Activated sludge*)

Quantity of sewage (*See Sewage flow rates*)

Racks (*See Bar racks*)

Safety: 19-6

OSHA standards

design: 19-6

equipment: 19-6

Sampling of wastewater: 18-4

Sand filtration: 15-5

subsurface: 6-2

Screens: 10-2

coarse (*See Bar racks*)

fine: 10-2

Scum

control in sedimentation tanks: 11-4

Secondary treatment: 3-4, 3-6

Sedimentation tanks

for activated sludge process: 13-6

for primary treatment: 11-2

for Trickling filter process: 12-4

Septic tank: 2-1, 6-2

applications: 2-1, 6-2

design: 6-2

disposal of effluent: 6-2

leaching fields: 6-2

Settling (*See Sedimentation*)

Sewage characteristics (*See Wastewater characteristics*)

Site selection: 2-2-2-3

Sludge, activated (*See Activated sludge*)

Sludge characteristics: 11-7

Sludge conditioning: 16-4

by chemical addition: 16-4

by physical means: 16-4

Sludge dewatering

by centrifugation: 16-5

on drying beds: 16-5

by belt press filtration: 16-5

by plate and frame filters: 16-5

by vacuum filtration: 16-5

Sludge digestion (*See Aerobic sludge digestion, Anaerobic sludge digestion*)

Sludge elutriation: 3-6, 18-3

Sludge gas (*See Digester gas*)

Sludge pumping: 16-2

piping: 16-2

pumps: 16-2

- Sludge thickeners
 - design
 - flotation: 16-3
 - stability: 16-3
 - solids loadings
 - flotation: 16-4
 - mechanical: 16-3
 - surface loading rates: 16-3
- Solids loadings
 - recommended values
 - for dissolved air flotation: 16-3
 - for sludge thickening: 16-3
- Stabilization ponds (*See Ponds, stabilization*)
- Step aeration activated sludge: 13-2 (*See also Activated sludge*)
- Suspended solids
 - removal by flotation: 10-5
- Temperature coefficients
 - for conventional biological treatment processes: 12-2
- Tertiary treatment (*See Advanced wastewater treatment*)
- Thickeners
 - flotation: 10-5, 16-3
 - mechanical: 16-3
- Thickening
 - practice: 16-3
 - theory
 - flotation: 10-5, 16-3
 - gravity: 16-3
- Toilets
 - chemical (*See Chemical toilets*)
 - incineration (*See Incineration toilets*)
 - waterless (*See Waterless toilets*)
- Toxic compounds: 3-1, 15-9
- Trickling filters: 7-2, 12-1-12-5
 - depth: 12-2
 - description of process: 3-3, 12-2
 - efficiency: 12-2
 - head losses: 12-3
 - loading: 12-2
 - NRC equations: 12-2
 - recirculation: 12-2
 - other representative equations: 12-2
 - underdrains: 12-2
 - ventilation: 12-2
- Two-stage digestion: 16-6

TM 5-814-3/AFM 88-11, Volume III

Underdrains

for trickling filters: 12-2

Vacuum filtration: 16-5

Venturi meter: 18-2

Volume of sewage (*See Sewage flow rates*)

Wastewater characteristics: 4-7

Wastewater treatment: 3-1-3-6

for small installations: 7-6

typical military process trains: 7-1-7-6

Waterless toilets: 6-3

Weir loadings

for primary sedimentation tanks: 11-2

Weirs: 7-1

for velocity control in grit chambers: 10-4