

**APPROVED FOR PUBLIC RELEASE; DISTRIBUTION IS UNLIMITED**

## **Grounding and Bonding in Command, Control, Communications, Computer, Intelligence, Surveillance, and Reconnaissance (C4ISR) Facilities**

		<i>Paragraph</i>	<i>Page</i>
CHAPTER 1.	INTRODUCTION		
	Purpose	1-1	1-1
	Scope	1-2	1-2
	Objectives	1-3	1-2
	References	1-4	1-2
	Overview of the inspection program	1-5	1-2
CHAPTER 2.	FACILITY ELEMENTS AND PROTECTION REQUIREMENTS		
	Generic C4ISR facility elements	2-1	2-1
	Element descriptions	2-2	2-1
	C4ISR facility protection requirements	2-3	2-17
	Role of grounding	2-4	2-26
	Role of bonding	2-5	2-27
	Role of shielding	2-6	2-28
CHAPTER 3.	FACILITY GROUND SYSTEM FOR NEW C4ISR FACILITIES		
	Ground systems	3-1	3-1
	Earth electrode subsystem	3-2	3-2
	Fault protection subsystem	3-3	3-17
	Lightning protection subsystem	3-4	3-30
	Signal reference subsystem.	3-5	3-58
CHAPTER 4.	ELECTROMAGNETIC INTERFERENCE (EMI) PROTECTION		
	Purpose of EMI protection	4-1	4-1
	Typical configuration	4-2	4-1
	Design considerations	4-3	4-2
	Typical components and installation details	4-4	4-7
	Interfaces with other grounding and bonding subsystems	4-5	4-18
	Inspections and testing	4-6	4-18
	Baseline configuration documentation	4-7	4-20
CHAPTER 5.	ELECTROMAGNETIC PULSE (EMP) PROTECTION		
	Purpose of EMP protection	5-1	5-1
	Types of EMP	5-2	5-1

	<i>Paragraph</i>	<i>Page</i>
	Effects of EMP on facility systems	5-3 5-2
	Grounding protection against EMP	5-4 5-3
	Typical components and installation details	5-5 5-4
	Interfaces with other grounding and bonding subsystems	5-6 5-5
	Inspections and testing	5-7 5-5
	Baseline configuration documentation	5-8 5-7
CHAPTER 6.	EVALUATING, MODIFYING, AND MAINTAINING EXISTING C4ISR FACILITIES	
	Purpose of evaluating, modifying and maintaining C4ISR facilities	6-1 6-1
	Facility survey	6-2 6-1
	Performance evaluation program	6-3 6-12
	Upgrades	6-4 6-12
	Expansions	6-5 6-14
CHAPTER 7.	MAINTENANCE OF GROUNDING AND BONDING SYSTEMS	
	Purpose of maintenance of grounding and bonding systems	7-1 7-1
	Configuration control	7-2 7-1
	Maintenance and repair records	7-3 7-1
	Earth electrode subsystem	7-4 7-2
	Fault protection subsystem	7-5 7-3
	Lightning protection subsystem	7-6 7-3
	Signal reference subsystem	7-7 7-4
	Facility shielding	7-8 7-5
	Performance evaluation program	7-9 7-5
APPENDIX A	REFERENCES	A-1
GLOSSARY		G-1

**LIST OF TABLES**

<i>Table</i>	<i>Title</i>	<i>Page</i>
2-1	Grounding and bonding principles for structures	2-3
2-2	Grounding and bonding principles for power distribution	2-7
2-3	Grounding and bonding principles for non-electrical utilities	2-8
2-4	Grounding and bonding principles for heating, ventilation, and air-conditioning	2-9
2-5	Grounding and bonding principles for earth electrode subsystem	2-10
2-6	Grounding and bonding principles for lightning protection	2-11
2-7	Grounding and bonding principles for communications	2-13
2-8	Grounding and bonding principles for computers and data processing	2-15
2-9	Grounding and bonding principles for controls	2-16
2-10	Grounding and bonding principles for personnel support equipment	2-17
3-1	Approximate soil resistivity	3-3
3-2	Relative advantages and disadvantages of the principal types of earth electrodes	3-6

**LIST OF TABLES (Continued)**

3-3	Minimum requirements for roof and down conductors on structures not greater than 75 feet (23 meters) in height	3-41
3-4	Minimum requirements for roof and down conductors on structures greater than 75 feet (23 meters) in height	3-42
3-5	Generalized characteristics for surge arresters by type	3-49
3-6	Typical withstand level limits for electrical devices	3-51
3-7	Size of equipment ground cables	3-65

**LIST OF FIGURES**

<i>Figure</i>	<i>Title</i>	<i>Page</i>
Figure 2-1	One-line diagram of a generic ac power subsystem	2-4
Figure 2-2	Typical ac power subsystem configuration	2-6
Figure 2-3	Required grounding for separately derived systems	2-20
Figure 2-4	Required grounding for non-separately derived systems	2-21
Figure 2-5	Recommended TEMPEST signal reference subsystem	2-25
Figure 2-6	Recommended power grounding for secure facilities	2-26
Figure 3-1	Earth electrode subsystem configuration for rectangular shaped facility	3-8
Figure 3-2	Earth electrode subsystem configuration for irregular shaped facility	3-10
Figure 3-3	Electrode configuration for closely adjacent structures	3-11
Figure 3-4	Typical grounding well installation	3-12
Figure 3-5	Sample of completed DA Form 7452-R	3-16
Figure 3-6	Grounding for fault protection	3-18
Figure 3-7	Typical equipment fault protection subsystem	3-20
Figure 3-8	Single-phase 120/240 volt ac power ground connection	3-21
Figure 3-9	Three-phase 120/208 volt ac power system ground connections	3-22
Figure 3-10	Single service entrance with common equipment grounding conductor	3-23
Figure 3-11	Single service entrance without common equipment grounding conductor	3-24
Figure 3-12	Sample of completed DA Form 7452-1-R	3-27
Figure 3-13	150-foot radius of protection	3-31
Figure 3-14	Mean annual number of thunderstorm days based on the period 1948 to 1972	3-32
Figure 3-15	Location of air terminals on gently sloping roofs	3-34
Figure 3-16	Location of air terminals for common roof types	3-35
Figure 3-17	Air terminal placement on flat-roofed structures	3-36
Figure 3-18	Lower roof protection for flat roof 25-feet or less high	3-37
Figure 3-19	Lower roof protection provided by pitched roof 25-feet or less high	3-38
Figure 3-20	Lower roof protection for flat roof 50-feet or less high	3-39
Figure 3-21	Lower roof protection for pitched roof 50-feet or less high	3-40
Figure 3-22	Criteria for dead end coverage	3-40
Figure 3-23	Recommended construction practices for integral lightning protection systems	3-43
Figure 3-24	Overhead ground wire lightning protection system	3-44
Figure 3-25	Secondary ac surge arrester installation, grounded service	3-47

## LIST OF FIGURES (Continued)

<i>Figure</i>	<i>Title</i>	<i>Page</i>
Figure 3-26	Secondary ac surge arrester installation, ungrounded service	3-48
Figure 3-27	Lightning protection for underground cables	3-52
Figure 3-28	Communication cable entry installation	3-54
Figure 3-29	Grounding details for elliptical waveguide	3-55
Figure 3-30	Ground strap fabrication details for elliptical waveguide	3-56
Figure 3-31	Sample of completed DA Form 7452-2-R	3-57
Figure 3-32	Floating signal ground	3-59
Figure 3-33	Single-point signal ground	3-60
Figure 3-34	Single-point ground bus system using separate risers	3-61
Figure 3-35	Single-point ground bus system using a common bus	3-62
Figure 3-36	Use of single-point ground configuration to minimize effect of facility ground currents	3-62
Figure 3-37	Signal coupling for lower frequency equipment	3-66
Figure 3-38	Sample of completed DA Form 7452-3-R	3-70
Figure 4-1	Connection of bonding jumpers to flat surface	4-12
Figure 4-2	Examples of bonding	4-13
Figure 6-1	Sample of completed DA Form 7452-4-R	6-2
Figure 6-2	Sample of completed DA Form 7452-5-R	6-3
Figure 6-3	Sample of completed DA Form 7452-6-R	6-4
Figure 6-4	Sample of completed DA Form 7452-7-R	6-5
Figure 6-5	Sample of completed DA Form 7452-8-R	6-6
Figure 6-6	Sample of completed DA Form 7452-9-R	6-7